

BLACK HILLS POWER, INC.
SD PUC DOCKET: EL14-061

REQUEST DATE : August 21, 2014
RESPONSE DATE : September 22, 2014
REQUESTING PARTY: SDPUC Staff

SDPUC Request No. 15:

On page 20 of the application, the Applicant states, "Fourteen residences are located within 150 feet of the proposed South Dakota route." Please provide a map, with similar resolution provided in *Q5*, identifying those fourteen residences.

Response to SDPUC Request No. 15:

Attachment 15.1 shows the 14 residences within 150 feet. This number was derived primarily through GIS mapping, and the actual number may vary based on hard survey data as it is developed. At the time the DEIS was prepared, there were approximately 14 residences within 150 feet of the proposed route. Since that time, minor route modifications and alternatives have been developed and the seven residences at Mountain Meadows will be avoided. Furthermore, the 7 residences within 150 feet at the HWY 44 crossing lie in a deep valley which would be spanned. The proposed conductor in this area would vary between 50 and 130 feet above those residences.

Attachments: 15.1 - Residences within 150 ft
15.2 – hwy44_plan
15.3 – hwy44_profile